

REPORT OF COMPLETED WORKS * SEACOAST FORTIFICATIONS
(Electric Plants)

COAST DEFENSES OF SAN FRANCISCO, CAL.
FORT MASON
POWER FOR 60" SEARCHLIGHT NO 9. ①


Form 5. Corrected to OCT.1,1921

	Serial No.	Type	Size	Mfgr.	Date of transfer	Cost	Con- dition	RPM	Belt or Direct Drive	Radiator: for Engine No.	Fuel	Switchboard			
												Material	No. of Panels	Gen. Feed	
Boiler No.1 No.2 No.3												See 675.1 (9th C.A.) 1			
Engine No.1 No.2 No.3	5495	GM 12	43/54 H.P	G.E.Co.	6/29/11	----- \$3,500.80 -----	Good	560	Direct		gasln.	Volts 115 DC	Wire 2	Used for GM Power No	
Generator No.1 No.2 No.3	189212	MPC 6	25-k.w.	do.	do.		do.	do.	do.						
Radiator No.1 No.2 No.3	None			Long-Turney	do.		do.	1050	do.	1					
Motor-generator No.1 No.2 No.3															
Switchboard Storage Battery Transformer No.1 No.2 No.3	67	B	20"x 82"	Walker Elect.Co.	do.			do.							Marble 1
Auxiliaries No.1 No.2 No.3															

DISTRIBUTION OF K.W. Projector and Controller 18-k.w.; Shelter .12-k.w.; Power Plant .46-k.w.--Total 18.6 k.w.

① See 675.1 (9th C.A.) 1
Approved H.D. project provides for its eventual reinstallation with S/L #13, Ft. Funston.


*POWER PLANT
SEARCHLIGHT N^o. 9 FT. MASON
SAN FRANCISCO, CAL.*



NOTE:~ For details of plant see
Transfer Plan 4-6-6 E.D. 38970/346

*POWER PLANT
SEARCHLIGHT N^o. 9 FT. MASON
SAN FRANCISCO, CAL.*

SCALE:~ $\frac{1}{8}$ IN. = 1 FT.



U.S. ENG. OFFICE 2ND DIST. SAN FRANCISCO, CAL. 4-6-7